

NFRC Product Certification Authorization Report



Manufacturer: Fleetwood Windows
Street: 1 Fleetwood Way
City/State/Zip: Corona, CA 92879

Product Series: EDGE |s| - OX Sliding Door
Product Type: DDSG
Air Leakage:

Simulation Lab: SWWW
Sim. Report #: FLE26001-SS
Sim. Report Date: 07/15/2026

Initial Cert. Date: 08/03/2021
Re-Certification Date: 07/16/2026
Revised Date: 01/01/1970

Print Date: 07/16/2026

Test Date: 05/28/2026

Expiration Date: 05/28/2031

CPD Number: FLE-M-120						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Index
	00075-00001	Clear/Arg 6mm SS-D	AU/AN	2		0.778	SS-D	Fill 1: ARG (90)	N		CL	0.55	0.70	0.77	19
	00076-00001	CIG366/Arg 6mm SS-D	AU/AN	2	0.02(2)	0.778	SS-D	Fill 1: ARG (90)	N		CL	0.37	0.26	0.61	20
	00077-00001	CIG272/Arg 6mm SS-D	AU/AN	2	0.042(2)	0.778	SS-D	Fill 1: ARG (90)	N		CL	0.38	0.39	0.67	20
	00078-00001	CIG180/Arg 6mm SS-D	AU/AN	2	0.068(2)	0.778	SS-D	Fill 1: ARG (90)	N		CL	0.39	0.59	0.74	20
	00079-00001	CIG340/Arg 6mm SS-D	AU/AN	2	0.028(2)	0.778	SS-D	Fill 1: ARG (90)	N		CL	0.38	0.18	0.36	20
	00080-00001	Clear-i89/Arg 6mm SS-D	AU/AN	2	0.149(4)	0.778	SS-D	Fill 1: ARG (90)	N		CL	0.43	0.64	0.75	18
	00081-00001	CIG366-i89/Arg 6mm SS-D	AU/AN	2	0.02(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	N		CL	0.32	0.26	0.59	18
	00082-00001	CIG272-i89/Arg 6mm SS-D	AU/AN	2	0.042(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	N		CL	0.32	0.38	0.66	18
	00083-00001	CIG180-i89/Arg 6mm SS-D	AU/AN	2	0.068(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	N		CL	0.33	0.57	0.72	18
	00084-00001	CIG340-i89/Arg 6mm SS-D	AU/AN	2	0.028(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	N		CL	0.32	0.17	0.36	18
	00085-00001	Clear/Arg 6mm SS-D	AU/AN	2		0.778	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.55	0.63	0.68	19
	00086-00001	CIG366/Arg 6mm SS-D	AU/AN	2	0.02(2)	0.778	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.37	0.24	0.54	20
	00087-00001	CIG272/Arg 6mm SS-D	AU/AN	2	0.042(2)	0.778	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.38	0.35	0.60	20
	00088-00001	CIG180/Arg 6mm SS-D	AU/AN	2	0.068(2)	0.778	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.39	0.53	0.66	20
	00089-00001	CIG340/Arg 6mm SS-D	AU/AN	2	0.028(2)	0.778	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.38	0.16	0.32	20
	00090-00001	Clear-i89/Arg 6mm SS-D	AU/AN	2	0.149(4)	0.778	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.43	0.57	0.67	18
	00091-00001	CIG366-i89/Arg 6mm SS-D	AU/AN	2	0.02(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.23	0.53	18
	00092-00001	CIG272-i89/Arg 6mm SS-D	AU/AN	2	0.042(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.34	0.58	18
	00093-00001	CIG180-i89/Arg 6mm SS-D	AU/AN	2	0.068(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.33	0.51	0.64	18
	00094-00001	CIG340-i89/Arg 6mm SS-D	AU/AN	2	0.028(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.15	0.32	18
	00095-00001	Clear/Arg 6mm SS-D	AU/AN	2		0.778	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.55	0.56	0.60	19
	00096-00001	CIG366/Arg 6mm SS-D	AU/AN	2	0.02(2)	0.778	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.37	0.21	0.47	20
	00097-00001	CIG272/Arg 6mm SS-D	AU/AN	2	0.042(2)	0.778	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.38	0.31	0.53	20
	00098-00001	CIG180/Arg 6mm SS-D	AU/AN	2	0.068(2)	0.778	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.39	0.47	0.58	20

NFRC Product Certification Authorization Report



Manufacturer: Fleetwood Windows
Street: 1 Fleetwood Way
City/State/Zip: Corona, CA 92879

Product Series: EDGE |s| - OX Sliding Door
Product Type: DDSG
Air Leakage:

Simulation Lab: SWWW
Sim. Report #: FLE26001-SS
Sim. Report Date: 07/15/2026

Initial Cert. Date: 08/03/2021
Re-Certification Date: 07/16/2026
Revised Date: 01/01/1970

Print Date: 07/16/2026

Test Date: 05/28/2026

Expiration Date: 05/28/2031

CPD Number: FLE-M-120						IA: National Accreditation And Management Institute										
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Index	
	00099-00001	CIG340/Arg 6mm SS-D	AU/AN	2	0.028(2)	0.778	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.38	0.15	0.28	20	
	00100-00001	Clear-i89/Arg 6mm SS-D	AU/AN	2	0.149(4)	0.778	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.43	0.50	0.59	18	
	00101-00001	CIG366-i89/Arg 6mm SS-D	AU/AN	2	0.02(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.21	0.46	18	
	00102-00001	CIG272-i89/Arg 6mm SS-D	AU/AN	2	0.042(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.30	0.51	18	
	00103-00001	CIG180-i89/Arg 6mm SS-D	AU/AN	2	0.068(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.33	0.45	0.56	18	
	00104-00001	CIG340-i89/Arg 6mm SS-D	AU/AN	2	0.028(2), 0.149(4)	0.778	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.14	0.28	18	
	00105-00001	Clear/Air 6mm A1-D	AU/AN	2		0.788	A1-D	Fill 1: AIR (100)	N		CL	0.57	0.68	0.76	19	
	00106-00001	SN68/Air 6mm A1-D	AU/AN	2	0.039(2)	0.788	A1-D	Fill 1: AIR (100)	N		CL	0.43	0.36	0.65	19	
	00107-00001	sBZ-SN68/Air 6mm A1-D	AU/AN	2	0.039(3)	0.788	A1-D	Fill 1: AIR (100)	N		BZ	0.43	0.30	0.39	19	
	00108-00001	SN68/Arg 6mm A1-D	AU/AN	2	0.039(2)	0.788	A1-D	Fill 1: ARG (90)	N		CL	0.39	0.36	0.65	19	
	00109-00001	SNX62/Air 6mm A1-D	AU/AN	2	0.02(2)	0.788	A1-D	Fill 1: AIR (100)	N		CL	0.42	0.26	0.59	19	
	00110-00001	SNX62/Arg 6mm A1-D	AU/AN	2	0.02(2)	0.788	A1-D	Fill 1: ARG (90)	N		CL	0.38	0.25	0.59	19	
	00111-00001	SNX70+/Arg 6mm A1-D	AU/AN	2	0.018(2)	0.788	A1-D	Fill 1: ARG (90)	N		CL	0.38	0.27	0.63	19	
	00112-00001	Clear/Air 6mm A1-D	AU/AN	2		0.788	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.57	0.61	0.68	19	
	00113-00001	SN68/Air 6mm A1-D	AU/AN	2	0.039(2)	0.788	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.43	0.32	0.58	19	
	00114-00001	sBZ-SN68/Air 6mm A1-D	AU/AN	2	0.039(3)	0.788	A1-D	Fill 1: AIR (100)	G	0.75	BZ	0.43	0.27	0.35	19	
	00115-00001	SN68/Arg 6mm A1-D	AU/AN	2	0.039(2)	0.788	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.39	0.32	0.58	19	
	00116-00001	SNX62/Air 6mm A1-D	AU/AN	2	0.02(2)	0.788	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.42	0.23	0.52	19	
	00117-00001	SNX62/Arg 6mm A1-D	AU/AN	2	0.02(2)	0.788	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.38	0.23	0.52	19	
	00118-00001	SNX70+/Arg 6mm A1-D	AU/AN	2	0.018(2)	0.788	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.38	0.24	0.56	19	
	00119-00001	Clear/Air 6mm A1-D	AU/AN	2		0.788	A1-D	Fill 1: AIR (100)	G	1.50	CL	0.57	0.54	0.60	19	
	00120-00001	SN68/Air 6mm A1-D	AU/AN	2	0.039(2)	0.788	A1-D	Fill 1: AIR (100)	G	1.50	CL	0.43	0.29	0.51	19	
	00121-00001	sBZ-SN68/Air 6mm A1-D	AU/AN	2	0.039(3)	0.788	A1-D	Fill 1: AIR (100)	G	1.50	BZ	0.43	0.24	0.30	19	
	00122-00001	SN68/Arg 6mm A1-D	AU/AN	2	0.039(2)	0.788	A1-D	Fill 1: ARG (90)	G	1.50	CL	0.39	0.29	0.51	19	
	00123-00001	SNX62/Air 6mm A1-D	AU/AN	2	0.02(2)	0.788	A1-D	Fill 1: AIR (100)	G	1.50	CL	0.42	0.21	0.46	19	

NFRC Product Certification Authorization Report



Manufacturer: Fleetwood Windows
Street: 1 Fleetwood Way
City/State/Zip: Corona, CA 92879

Product Series: EDGE |s| - OX Sliding Door
Product Type: DDSG
Air Leakage:

Simulation Lab: SWWW
Sim. Report #: FLE26001-SS
Sim. Report Date: 07/15/2026

Initial Cert. Date: 08/03/2021
Re-Certification Date: 07/16/2026
Revised Date: 01/01/1970

Print Date: 07/16/2026

Test Date: 05/28/2026

Expiration Date: 05/28/2031

CPD Number: FLE-M-120						IA: National Accreditation And Management Institute										
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Index	
	00124-00001	SNX62/Arg 6mm A1-D	AU/AN	2	0.02(2)	0.788	A1-D	Fill 1: ARG (90)	G	1.50	CL	0.38	0.21	0.46	19	
	00125-00001	SNX70+/Arg 6mm A1-D	AU/AN	2	0.018(2)	0.788	A1-D	Fill 1: ARG (90)	G	1.50	CL	0.38	0.22	0.49	19	
	00126-00001	Clear/Arg 6mm TS-D	AU/AN	2		0.784	TS-D	Fill 1: ARG (90)	N		CL	0.55	0.68	0.76	19	
	00127-00001	SN68/Arg 6mm TS-D	AU/AN	2	0.039(2)	0.784	TS-D	Fill 1: ARG (90)	N		CL	0.38	0.36	0.65	20	
	00128-00001	SNX62/Arg 6mm TS-D	AU/AN	2	0.02(2)	0.784	TS-D	Fill 1: ARG (90)	N		CL	0.37	0.25	0.59	20	
	00129-00001	SNX70+/Arg 6mm TS-D	AU/AN	2	0.018(2)	0.784	TS-D	Fill 1: ARG (90)	N		CL	0.37	0.27	0.63	20	
	00130-00001	Clear-IS20/Arg 6mm TS-D	AU/AN	2	0.198(4)	0.784	TS-D	Fill 1: ARG (90)	N		CL	0.44	0.64	0.75	18	
	00131-00001	SN68-IS20/Arg 6mm TS-D	AU/AN	2	0.039(2), 0.198(4)	0.784	TS-D	Fill 1: ARG (90)	N		CL	0.33	0.35	0.64	18	
	00132-00001	SNX62-IS20/Arg 6mm TS-D	AU/AN	2	0.02(2), 0.198(4)	0.784	TS-D	Fill 1: ARG (90)	N		CL	0.32	0.25	0.58	18	
	00133-00001	Clear/Arg 6mm TS-D	AU/AN	2		0.784	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.55	0.61	0.68	19	
	00134-00001	SN68/Arg 6mm TS-D	AU/AN	2	0.039(2)	0.784	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.38	0.32	0.58	20	
	00135-00001	SNX62/Arg 6mm TS-D	AU/AN	2	0.02(2)	0.784	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.37	0.23	0.52	20	
	00136-00001	SNX70+/Arg 6mm TS-D	AU/AN	2	0.018(2)	0.784	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.37	0.24	0.56	20	
	00137-00001	Clear-IS20/Arg 6mm TS-D	AU/AN	2	0.198(4)	0.784	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.44	0.57	0.66	18	
	00138-00001	SN68-IS20/Arg 6mm TS-D	AU/AN	2	0.039(2), 0.198(4)	0.784	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.33	0.31	0.56	18	
	00139-00001	SNX62-IS20/Arg 6mm TS-D	AU/AN	2	0.02(2), 0.198(4)	0.784	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.22	0.51	18	
	00140-00001	Clear/Arg 6mm TS-D	AU/AN	2		0.784	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.55	0.54	0.60	19	
	00141-00001	SN68/Arg 6mm TS-D	AU/AN	2	0.039(2)	0.784	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.38	0.29	0.51	20	
	00142-00001	SNX62/Arg 6mm TS-D	AU/AN	2	0.02(2)	0.784	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.37	0.21	0.46	20	
	00143-00001	SNX70+/Arg 6mm TS-D	AU/AN	2	0.018(2)	0.784	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.37	0.22	0.49	20	
	00144-00001	Clear-IS20/Arg 6mm TS-D	AU/AN	2	0.198(4)	0.784	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.44	0.51	0.58	18	
	00145-00001	SN68-IS20/Arg 6mm TS-D	AU/AN	2	0.039(2), 0.198(4)	0.784	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.33	0.28	0.50	18	
	00146-00001	SNX62-IS20/Arg 6mm TS-D	AU/AN	2	0.02(2), 0.198(4)	0.784	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.20	0.45	18	
	00147-00001	Clear/Arg 6mm TP-D	AU/AN	2		0.750	TP-D	Fill 1: ARG (90)	N		CL	0.55	0.68	0.76	19	
	00148-00001	SN68/Arg 6mm TP-D	AU/AN	2	0.039(2)	0.750	TP-D	Fill 1: ARG (90)	N		CL	0.38	0.36	0.65	20	

NFRC Product Certification Authorization Report



Manufacturer: Fleetwood Windows
Street: 1 Fleetwood Way
City/State/Zip: Corona, CA 92879

Product Series: EDGE |s| - OX Sliding Door
Product Type: DDSG
Air Leakage:

Simulation Lab: SWWW
Sim. Report #: FLE26001-SS
Sim. Report Date: 07/15/2026

Initial Cert. Date: 08/03/2021
Re-Certification Date: 07/16/2026
Revised Date: 01/01/1970

Print Date: 07/16/2026

Test Date: 05/28/2026

Expiration Date: 05/28/2031

CPD Number: FLE-M-120						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Index
	00149-00001	SNX62/Arg 6mm TP-D	AU/AN	2	0.02(2)	0.750	TP-D	Fill 1: ARG (90)	N		CL	0.37	0.25	0.59	20
	00150-00001	SNX70+/Arg 6mm TP-D	AU/AN	2	0.018(2)	0.750	TP-D	Fill 1: ARG (90)	N		CL	0.37	0.27	0.63	20
	00151-00001	Clear-IS20/Arg 6mm TP-D	AU/AN	2	0.198(4)	0.750	TP-D	Fill 1: ARG (90)	N		CL	0.44	0.64	0.75	18
	00152-00001	SN68-IS20/Arg 6mm TP-D	AU/AN	2	0.039(2), 0.198(4)	0.750	TP-D	Fill 1: ARG (90)	N		CL	0.33	0.35	0.64	19
	00153-00001	SNX62-IS20/Arg 6mm TP-D	AU/AN	2	0.02(2), 0.198(4)	0.750	TP-D	Fill 1: ARG (90)	N		CL	0.32	0.25	0.58	19
	00154-00001	Clear/Arg 6mm TP-D	AU/AN	2		0.750	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.55	0.61	0.68	19
	00155-00001	SN68/Arg 6mm TP-D	AU/AN	2	0.039(2)	0.750	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.38	0.32	0.58	20
	00156-00001	SNX62/Arg 6mm TP-D	AU/AN	2	0.02(2)	0.750	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.37	0.23	0.52	20
	00157-00001	SNX70+/Arg 6mm TP-D	AU/AN	2	0.018(2)	0.750	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.37	0.24	0.56	20
	00158-00001	Clear-IS20/Arg 6mm TP-D	AU/AN	2	0.198(4)	0.750	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.44	0.57	0.66	18
	00159-00001	SN68-IS20/Arg 6mm TP-D	AU/AN	2	0.039(2), 0.198(4)	0.750	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.33	0.31	0.56	19
	00160-00001	SNX62-IS20/Arg 6mm TP-D	AU/AN	2	0.02(2), 0.198(4)	0.750	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.22	0.51	19
	00161-00001	Clear/Arg 6mm TP-D	AU/AN	2		0.750	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.55	0.54	0.60	19
	00162-00001	SN68/Arg 6mm TP-D	AU/AN	2	0.039(2)	0.750	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.38	0.29	0.51	20
	00163-00001	SNX62/Arg 6mm TP-D	AU/AN	2	0.02(2)	0.750	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.37	0.21	0.46	20
	00164-00001	SNX70+/Arg 6mm TP-D	AU/AN	2	0.018(2)	0.750	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.37	0.21	0.49	20
	00165-00001	Clear-IS20/Arg 6mm TP-D	AU/AN	2	0.198(4)	0.750	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.44	0.51	0.58	18
	00166-00001	SN68-IS20/Arg 6mm TP-D	AU/AN	2	0.039(2), 0.198(4)	0.750	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.33	0.28	0.50	19
	00167-00001	SNX62-IS20/Arg 6mm TP-D	AU/AN	2	0.02(2), 0.198(4)	0.750	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.20	0.45	19
	00168-00001	Clear/Arg 8mm SS-D	AU/AN	2		0.632	SS-D	Fill 1: ARG (90)	N		CL	0.54	0.67	0.75	20
	00169-00001	CIG366/Arg 8mm SS-D	AU/AN	2	0.02(2)	0.632	SS-D	Fill 1: ARG (90)	N		CL	0.37	0.26	0.59	20
	00170-00001	CIG272/Arg 8mm SS-D	AU/AN	2	0.042(2)	0.632	SS-D	Fill 1: ARG (90)	N		CL	0.37	0.38	0.66	20
	00171-00001	CIG180/Arg 8mm SS-D	AU/AN	2	0.068(2)	0.632	SS-D	Fill 1: ARG (90)	N		CL	0.38	0.56	0.72	20
	00172-00001	CIG340/Arg 8mm SS-D	AU/AN	2	0.028(2)	0.632	SS-D	Fill 1: ARG (90)	N		CL	0.37	0.18	0.36	20
	00173-00001	Clear-i89/Arg 8mm SS-D	AU/AN	2	0.149(4)	0.632	SS-D	Fill 1: ARG (90)	N		CL	0.43	0.60	0.74	18

NFRC Product Certification Authorization Report



Manufacturer: Fleetwood Windows
Street: 1 Fleetwood Way
City/State/Zip: Corona, CA 92879

Product Series: EDGE |s| - OX Sliding Door
Product Type: DDSG
Air Leakage:

Simulation Lab: SWWW
Sim. Report #: FLE26001-SS
Sim. Report Date: 07/15/2026

Initial Cert. Date: 08/03/2021
Re-Certification Date: 07/16/2026
Revised Date: 01/01/1970

Print Date: 07/16/2026

Test Date: 05/28/2026

Expiration Date: 05/28/2031

CPD Number: FLE-M-120						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Index
	00174-00001	CIG366-i89/Arg 8mm SS-D	AU/AN	2	0.02(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	N		CL	0.31	0.25	0.58	18
	00175-00001	CIG272-i89/Arg 8mm SS-D	AU/AN	2	0.042(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	N		CL	0.32	0.37	0.64	18
	00176-00001	CIG180-i89/Arg 8mm SS-D	AU/AN	2	0.068(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	N		CL	0.32	0.54	0.71	18
	00177-00001	CIG340-i89/Arg 8mm SS-D	AU/AN	2	0.028(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	N		CL	0.32	0.17	0.35	18
	00178-00001	Clear/Arg 8mm SS-D	AU/AN	2		0.632	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.54	0.60	0.67	20
	00179-00001	CIG366/Arg 8mm SS-D	AU/AN	2	0.02(2)	0.632	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.37	0.23	0.53	20
	00180-00001	CIG272/Arg 8mm SS-D	AU/AN	2	0.042(2)	0.632	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.37	0.34	0.58	20
	00181-00001	CIG180/Arg 8mm SS-D	AU/AN	2	0.068(2)	0.632	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.38	0.50	0.64	20
	00182-00001	CIG340/Arg 8mm SS-D	AU/AN	2	0.028(2)	0.632	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.37	0.16	0.32	20
	00183-00001	Clear-i89/Arg 8mm SS-D	AU/AN	2	0.149(4)	0.632	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.43	0.54	0.65	18
	00184-00001	CIG366-i89/Arg 8mm SS-D	AU/AN	2	0.02(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.31	0.23	0.51	18
	00185-00001	CIG272-i89/Arg 8mm SS-D	AU/AN	2	0.042(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.33	0.57	18
	00186-00001	CIG180-i89/Arg 8mm SS-D	AU/AN	2	0.068(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.48	0.63	18
	00187-00001	CIG340-i89/Arg 8mm SS-D	AU/AN	2	0.028(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.15	0.31	18
	00188-00001	Clear/Arg 8mm SS-D	AU/AN	2		0.632	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.54	0.53	0.59	20
	00189-00001	CIG366/Arg 8mm SS-D	AU/AN	2	0.02(2)	0.632	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.37	0.21	0.46	20
	00190-00001	CIG272/Arg 8mm SS-D	AU/AN	2	0.042(2)	0.632	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.37	0.30	0.51	20
	00191-00001	CIG180/Arg 8mm SS-D	AU/AN	2	0.068(2)	0.632	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.38	0.45	0.57	20
	00192-00001	CIG340/Arg 8mm SS-D	AU/AN	2	0.028(2)	0.632	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.37	0.14	0.28	20
	00193-00001	Clear-i89/Arg 8mm SS-D	AU/AN	2	0.149(4)	0.632	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.43	0.48	0.57	18
	00194-00001	CIG366-i89/Arg 8mm SS-D	AU/AN	2	0.02(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.31	0.21	0.45	18
	00195-00001	CIG272-i89/Arg 8mm SS-D	AU/AN	2	0.042(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.29	0.50	18
	00196-00001	CIG180-i89/Arg 8mm SS-D	AU/AN	2	0.068(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.43	0.55	18
	00197-00001	CIG340-i89/Arg 8mm SS-D	AU/AN	2	0.028(2), 0.149(4)	0.632	SS-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.14	0.27	18
	00198-00001	Clear/Air 10mm A1-D	AU/AN	2		0.476	A1-D	Fill 1: AIR (100)	N		CL	0.56	0.67	0.76	20

NFRC Product Certification Authorization Report



Manufacturer: Fleetwood Windows **Product Series:** EDGE |s| - OX Sliding Door **Simulation Lab:** SWWW **Initial Cert. Date:** 08/03/2021
Street: 1 Fleetwood Way **Product Type:** DDSG **Sim. Report #:** FLE26001-SS **Re-Certification Date:** 07/16/2026
City/State/Zip: Corona, CA 92879 **Air Leakage:** **Sim. Report Date:** 07/15/2026 **Revised Date:** 01/01/1970
Print Date: 07/16/2026 **Test Date:** 05/28/2026 **Expiration Date:** 05/28/2031

CPD Number: FLE-M-120						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Index
	00199-00001	SN68/Air 10mm A1-D	AU/AN	2	0.039(2)	0.476	A1-D	Fill 1: AIR (100)	N		CL	0.41	0.36	0.64	20
	00200-00001	sBZ-SN68/Air 10mm A1-D	AU/AN	2	0.039(3)	0.476	A1-D	Fill 1: AIR (100)	N		BZ	0.41	0.24	0.27	20
	00201-00001	SN68/Arg 10mm A1-D	AU/AN	2	0.039(2)	0.476	A1-D	Fill 1: ARG (90)	N		CL	0.37	0.35	0.64	20
	00202-00001	SNX62/Air 10mm A1-D	AU/AN	2	0.02(2)	0.476	A1-D	Fill 1: AIR (100)	N		CL	0.40	0.26	0.58	20
	00203-00001	SNX62/Arg 10mm A1-D	AU/AN	2	0.02(2)	0.476	A1-D	Fill 1: ARG (90)	N		CL	0.36	0.25	0.58	20
	00204-00001	SNX70+/Arg 10mm A1-D	AU/AN	2	0.018(2)	0.476	A1-D	Fill 1: ARG (90)	N		CL	0.36	0.27	0.62	20
	00205-00001	Clear/Air 10mm A1-D	AU/AN	2		0.476	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.56	0.60	0.67	20
	00206-00001	SN68/Air 10mm A1-D	AU/AN	2	0.039(2)	0.476	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.41	0.32	0.57	20
	00207-00001	sBZ-SN68/Air 10mm A1-D	AU/AN	2	0.039(3)	0.476	A1-D	Fill 1: AIR (100)	G	0.75	BZ	0.41	0.22	0.24	20
	00208-00001	SN68/Arg 10mm A1-D	AU/AN	2	0.039(2)	0.476	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.37	0.32	0.57	20
	00209-00001	SNX62/Air 10mm A1-D	AU/AN	2	0.02(2)	0.476	A1-D	Fill 1: AIR (100)	G	0.75	CL	0.40	0.24	0.51	20
	00210-00001	SNX62/Arg 10mm A1-D	AU/AN	2	0.02(2)	0.476	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.36	0.23	0.51	20
	00211-00001	SNX70+/Arg 10mm A1-D	AU/AN	2	0.018(2)	0.476	A1-D	Fill 1: ARG (90)	G	0.75	CL	0.36	0.24	0.55	20
	00212-00001	Clear/Air 10mm A1-D	AU/AN	2		0.476	A1-D	Fill 1: AIR (100)	G	1.50	CL	0.56	0.53	0.59	20
	00213-00001	SN68/Air 10mm A1-D	AU/AN	2	0.039(2)	0.476	A1-D	Fill 1: AIR (100)	G	1.50	CL	0.41	0.29	0.50	20
	00214-00001	sBZ-SN68/Air 10mm A1-D	AU/AN	2	0.039(3)	0.476	A1-D	Fill 1: AIR (100)	G	1.50	BZ	0.41	0.20	0.21	20
	00215-00001	SN68/Arg 10mm A1-D	AU/AN	2	0.039(2)	0.476	A1-D	Fill 1: ARG (90)	G	1.50	CL	0.37	0.28	0.50	20
	00216-00001	SNX62/Air 10mm A1-D	AU/AN	2	0.02(2)	0.476	A1-D	Fill 1: AIR (100)	G	1.50	CL	0.40	0.21	0.45	20
	00217-00001	SNX62/Arg 10mm A1-D	AU/AN	2	0.02(2)	0.476	A1-D	Fill 1: ARG (90)	G	1.50	CL	0.36	0.21	0.45	20
	00218-00001	SNX70+/Arg 10mm A1-D	AU/AN	2	0.018(2)	0.476	A1-D	Fill 1: ARG (90)	G	1.50	CL	0.36	0.22	0.48	20
	00219-00001	Clear/Arg 10mm TS-D	AU/AN	2		0.440	TS-D	Fill 1: ARG (90)	N		CL	0.54	0.67	0.76	20
	00220-00001	SN68/Arg 10mm TS-D	AU/AN	2	0.039(2)	0.440	TS-D	Fill 1: ARG (90)	N		CL	0.37	0.35	0.64	21
	00221-00001	SNX62/Arg 10mm TS-D	AU/AN	2	0.02(2)	0.440	TS-D	Fill 1: ARG (90)	N		CL	0.36	0.26	0.58	21
	00222-00001	SNX70+/Arg 10mm TS-D	AU/AN	2	0.018(2)	0.440	TS-D	Fill 1: ARG (90)	N		CL	0.36	0.27	0.62	21
	00223-00001	Clear-IS20/Arg 10mm TS-D	AU/AN	2	0.198(4)	0.440	TS-D	Fill 1: ARG (90)	N		CL	0.44	0.61	0.73	19

NFRC Product Certification Authorization Report



Manufacturer: Fleetwood Windows **Product Series:** EDGE |s| - OX Sliding Door **Simulation Lab:** SWWW **Initial Cert. Date:** 08/03/2021
Street: 1 Fleetwood Way **Product Type:** DDSG **Sim. Report #:** FLE26001-SS **Re-Certification Date:** 07/16/2026
City/State/Zip: Corona, CA 92879 **Air Leakage:** **Sim. Report Date:** 07/15/2026 **Revised Date:** 01/01/1970
Print Date: 07/16/2026 **Test Date:** 05/28/2026 **Expiration Date:** 05/28/2031

CPD Number: FLE-M-120						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Index
	00224-00001	SN68-IS20/Arg 10mm TS-D	AU/AN	2	0.039(2), 0.198(4)	0.440	TS-D	Fill 1: ARG (90)	N		CL	0.32	0.34	0.62	19
	00225-00001	SNX62-IS20/Arg 10mm TS-D	AU/AN	2	0.02(2), 0.198(4)	0.440	TS-D	Fill 1: ARG (90)	N		CL	0.32	0.25	0.56	19
	00226-00001	Clear/Arg 10mm TS-D	AU/AN	2		0.440	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.54	0.60	0.67	20
	00227-00001	SN68/Arg 10mm TS-D	AU/AN	2	0.039(2)	0.440	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.37	0.32	0.57	21
	00228-00001	SNX62/Arg 10mm TS-D	AU/AN	2	0.02(2)	0.440	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.36	0.23	0.51	21
	00229-00001	SNX70+/Arg 10mm TS-D	AU/AN	2	0.018(2)	0.440	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.36	0.24	0.55	21
	00230-00001	Clear-IS20/Arg 10mm TS-D	AU/AN	2	0.198(4)	0.440	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.44	0.55	0.65	19
	00231-00001	SN68-IS20/Arg 10mm TS-D	AU/AN	2	0.039(2), 0.198(4)	0.440	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.31	0.55	19
	00232-00001	SNX62-IS20/Arg 10mm TS-D	AU/AN	2	0.02(2), 0.198(4)	0.440	TS-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.22	0.50	19
	00233-00001	Clear/Arg 10mm TS-D	AU/AN	2		0.440	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.54	0.53	0.59	20
	00234-00001	SN68/Arg 10mm TS-D	AU/AN	2	0.039(2)	0.440	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.37	0.28	0.50	21
	00235-00001	SNX62/Arg 10mm TS-D	AU/AN	2	0.02(2)	0.440	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.36	0.21	0.45	21
	00236-00001	SNX70+/Arg 10mm TS-D	AU/AN	2	0.018(2)	0.440	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.36	0.22	0.48	21
	00237-00001	Clear-IS20/Arg 10mm TS-D	AU/AN	2	0.198(4)	0.440	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.44	0.49	0.57	19
	00238-00001	SN68-IS20/Arg 10mm TS-D	AU/AN	2	0.039(2), 0.198(4)	0.440	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.27	0.48	19
	00239-00001	SNX62-IS20/Arg 10mm TS-D	AU/AN	2	0.02(2), 0.198(4)	0.440	TS-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.20	0.44	19
	00240-00001	Clear/Arg 10mm TP-D	AU/AN	2		0.438	TP-D	Fill 1: ARG (90)	N		CL	0.54	0.67	0.76	20
	00241-00001	SN68/Arg 10mm TP-D	AU/AN	2	0.039(2)	0.438	TP-D	Fill 1: ARG (90)	N		CL	0.37	0.35	0.64	21
	00242-00001	SNX62/Arg 10mm TP-D	AU/AN	2	0.02(2)	0.438	TP-D	Fill 1: ARG (90)	N		CL	0.36	0.26	0.58	21
	00243-00001	SNX70+/Arg 10mm TP-D	AU/AN	2	0.018(2)	0.438	TP-D	Fill 1: ARG (90)	N		CL	0.36	0.27	0.62	21
	00244-00001	Clear-IS20/Arg 10mm TP-D	AU/AN	2	0.198(4)	0.438	TP-D	Fill 1: ARG (90)	N		CL	0.44	0.61	0.73	19
	00245-00001	SN68-IS20/Arg 10mm TP-D	AU/AN	2	0.039(2), 0.198(4)	0.438	TP-D	Fill 1: ARG (90)	N		CL	0.32	0.34	0.62	19
	00246-00001	SNX62-IS20/Arg 10mm TP-D	AU/AN	2	0.02(2), 0.198(4)	0.438	TP-D	Fill 1: ARG (90)	N		CL	0.32	0.25	0.56	19
	00247-00001	Clear/Arg 10mm TP-D	AU/AN	2		0.438	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.54	0.60	0.67	20
	00248-00001	SN68/Arg 10mm TP-D	AU/AN	2	0.039(2)	0.438	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.37	0.32	0.57	21

NFRC Product Certification Authorization Report



Manufacturer: Fleetwood Windows **Product Series:** EDGE |s| - OX Sliding Door **Simulation Lab:** SWWW **Initial Cert. Date:** 08/03/2021
Street: 1 Fleetwood Way **Product Type:** DDSG **Sim. Report #:** FLE26001-SS **Re-Certification Date:** 07/16/2026
City/State/Zip: Corona, CA 92879 **Air Leakage:** **Sim. Report Date:** 07/15/2026 **Revised Date:** 01/01/1970
Print Date: 07/16/2026 **Test Date:** 05/28/2026 **Expiration Date:** 05/28/2031

CPD Number: FLE-M-120						IA: National Accreditation And Management Institute									
Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Index
	00249-00001	SNX62/Arg 10mm TP-D	AU/AN	2	0.02(2)	0.438	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.36	0.23	0.51	21
	00250-00001	SNX70+/Arg 10mm TP-D	AU/AN	2	0.018(2)	0.438	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.36	0.24	0.55	21
	00251-00001	Clear-IS20/Arg 10mm TP-D	AU/AN	2	0.198(4)	0.438	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.44	0.55	0.65	19
	00252-00001	SN68-IS20/Arg 10mm TP-D	AU/AN	2	0.039(2), 0.198(4)	0.438	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.31	0.55	19
	00253-00001	SNX62-IS20/Arg 10mm TP-D	AU/AN	2	0.02(2), 0.198(4)	0.438	TP-D	Fill 1: ARG (90)	G	0.75	CL	0.32	0.22	0.50	19
	00254-00001	Clear/Arg 10mm TP-D	AU/AN	2		0.438	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.54	0.53	0.59	20
	00255-00001	SN68/Arg 10mm TP-D	AU/AN	2	0.039(2)	0.438	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.37	0.28	0.50	21
	00256-00001	SNX62/Arg 10mm TP-D	AU/AN	2	0.02(2)	0.438	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.36	0.21	0.45	21
	00257-00001	SNX70+/Arg 10mm TP-D	AU/AN	2	0.018(2)	0.438	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.36	0.22	0.48	21
	00258-00001	Clear-IS20/Arg 10mm TP-D	AU/AN	2	0.198(4)	0.438	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.44	0.49	0.57	19
	00259-00001	SN68-IS20/Arg 10mm TP-D	AU/AN	2	0.039(2), 0.198(4)	0.438	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.27	0.48	19
	00260-00001	SNX62-IS20/Arg 10mm TP-D	AU/AN	2	0.02(2), 0.198(4)	0.438	TP-D	Fill 1: ARG (90)	G	1.50	CL	0.32	0.20	0.44	19

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TATF	05/28/2026	1978mm x 2007mm	0.409	0.394	T6447.01-301-46

Comments: N/A.

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA
Signature:

